

Date: November 3, 2016  
To: Ben Holt  
From: Jim Sawyer

RE: Heflin Property Special Exception Category 20      SPEX-16-006017      PIN: 6994-37-9397

1. Applicant shall show location of treatment unit(s) (Zoning Ordinance 5-2001.2.F.).
2. Applicant shall show correct location of discharge point and show the 250 feet of ditch to demonstrate that no off-site easement is required (ZO 5-2001.2.H).
3. Applicant shall show setbacks of treatment unit(s), discharge point and treatment path from wells and property lines (ZO 5-2001.2.I). Location on scaled drawing is sufficient.
4. Describe proposed treatment unit(s) (ZO 5-2001.2.M)
5. Applicant shall label discharge point as “dry ditch” (ZO 5-2001.2.O).